

Section: General Rules

Heavy Industrial Improvements

Subject: General

Summary

This section contains definitions for the valuation of heavy industrial buildings and structures, oil and gas well resource production equipment, mine resource production equipment and pipelines.

Heavy Industrial Buildings and Structures and Oil & Gas Well Buildings and Structures

The replacement cost new, physical deterioration, functional obsolescence and closure adjustment factor for heavy industrial buildings or structures shall be determined in accordance with the valuation procedures in:

- Chapter 1 – Regulated Property, Section 1.1.7 – Regulated Property, Heavy Industrial Buildings and Structures
- Chapter 3 – Heavy Industrial Improvements; and
- Marshall & Swift Valuation Service.

Buildings and structures located at a Shut-In Single Well Site or a Shut-In Multi-Well Pad Site, as defined in Chapter 4 - Resource Production Equipment, Section 4.1.1 – Oil and Gas Well Resource Equipment, General Rules, shall have a 99% shut-in allowance applied to the buildings and structures replacement cost new. The 99% allowance shall only be applied to the buildings and structures once the tank(s) on the shut-in site are rendered unusable.

Oil and Gas Well Resource Production Equipment

The replacement cost new, physical deterioration, downtime allowance, and production adjustment factor for oil and gas well resource production equipment shall be determined in accordance with valuation procedures in Chapter 4 - Resource Production Equipment, Section 4.1 - Oil and Gas Well Resource Production Equipment.

Mine Resource Production Equipment

The replacement cost new, physical deterioration, downtime allowance, and downtime adjustment factor for mine resource production equipment shall be determined in accordance with the valuation procedures in Chapter 4 - Resource Production Equipment, Section 4.2 - Mine Resource Production Equipment.

Pipelines

The replacement cost new, physical deterioration, and volume adjustment factor for pipelines shall be determined in accordance with the valuation procedures in Chapter 5 - Pipelines.

Section: General Rules

Heavy Industrial Improvements

Subject: General

Section: General Rules

Heavy Industrial Improvements

Subject: Replacement Cost New

Summary

This section contains the valuation procedures for determining the replacement cost new for heavy industrial buildings and structures.

Use of Rate Schedules

Where a rate schedule does not state the units of comparison, the units of comparison are dollars per square foot (\$/sq.ft.).

Where a rate schedule does not contain a rate, factor or multiplier for a specific dimension or size, mathematical interpolation of the next highest and next lowest rate, factor or multiplier is used to calculate the required rate, factor or multiplier.

Where a rate schedule contains an extension rate, the extension rate is applied to all units of comparison greater than the next lowest size or dimension.

Measurement of Buildings and Structures

All building and structure measurements are imperial or metric standards. Linear measurements are determined to the nearest half foot.

The floor area of a building or structure or a section of a building or structure includes the interior partitions, elevators, stairways and exterior walls.

The floor area of a building or structure or a section of a building or structure is measured to the outside finished surface of the exterior walls, unless otherwise specified.

Unit of Comparison

The units of comparison should be imperial or their metric equivalent.

Section: General Rules

Heavy Industrial Improvements

Subject: Replacement Cost New

The following are the units of comparison and their application for determining the replacement cost new of buildings and structures.

Type	Units of Comparison	Abbreviation
Section Area	Square Feet	sq.ft.
Unit Area	Square Feet	sq.ft.
Floor Area	Square Feet	sq.ft.
Surface Area	Square Feet	sq.ft.
Base Area	Square Feet	sq.ft.
Building Volume	Cubic Feet	cu.ft.
	Bushels	bushels
Tank Volume	Imperial Gallons	imp. gal.
	U.S. Gallons	USG
	Imperial Barrels	barrels
	Cubic Meters	M ³
Bin Volume	Bushels	bushels
Elevator Volume	Bushels	bushels
Structure Volume	Pounds per Hour	lb./hr.
Structure Height	Feet	ft.
Structure Length	Feet	ft.
Perimeter	Feet	ft.
Structural Unit	Unit	unit
Reservoir	Acre Foot	a.f.
	Imperial Gallons	imp. gal.
	U.S. Gallons	USG
Power Generation	Megawatt	MW

General

The replacement cost new of heavy industrial buildings or structures shall be determined by calculating the cost of construction using the calculator method, unit-in-place cost method, segregated cost method or trended original cost method. The methods shall be applied in accordance with the valuation procedures in the Marshall & Swift Valuation Service, or in the case of non-standard buildings and structures in Chapter 3 - Heavy Industrial Improvements, Non-standard Buildings and Structures.

Climate Rating

When using the Marshall & Swift Valuation Service for the calculator method, the unit-in-place cost method and the segregated cost method, the extreme climate cost adjustments shall be used for heating, ventilation and air conditioning (HVAC).

Calculator Method

The calculator method for determining replacement cost new is used where a heavy industrial building or structure can be classified in accordance with the classification guidelines in the Marshall & Swift Valuation Service, Calculator Method or in the case of non-standard buildings and structures in Chapter 3 - Heavy Industrial Improvements, Non-standard Buildings and Structures.

The replacement cost new using the calculator method is determined by application of the following calculation procedure:

1. Determine the occupancy code for the building or structure;
2. Determine the building attributes required to calculate the replacement cost new from the classification and calculation procedures for the specific occupancy code; and
3. Calculate the replacement cost new in accordance with the calculation procedures for the specific occupancy code.

Unit-in-place Cost Method

The unit-in-place cost method for determining replacement cost new shall be used where a specific heavy industrial building or structure attribute cannot be classified in accordance with the classification guidelines for the calculator method, and can be classified in accordance with the unit-in-place classification guidelines, rate schedules, and calculation procedures in the Marshall & Swift Valuation Service, Unit-In-Place Costs, Sections 51 to 67.

Where a building or structure cannot be classified in accordance with the classification guidelines for the calculator method, the replacement cost new shall be determined by application of the following calculation procedure:

1. Determine the structural components that comprise the building or structure;
2. Determine the unit-in-place cost for each structural component;
3. Calculate the replacement cost new for each structural component by multiplying the unit-in-place cost by the number of units; and
4. Calculate the replacement cost new of the building or structure by summing the replacement cost new of the structural components.

Segregated Cost Method

The segregated cost method for determining replacement cost new shall be used where a specific heavy industrial building or structure attribute cannot be classified in accordance with the classification guidelines for the calculator method, or the unit-in-place cost method, and can be classified in accordance with the segregated cost classification guidelines, rate schedules, and calculation procedures in the Marshall & Swift Valuation Service, Segregated Method.

Section: General Rules

Heavy Industrial Improvements

Subject: Replacement Cost New

Trended Original Cost Method

The trended original cost method for determining replacement cost new shall be used where a specific heavy industrial building or structural attribute cannot be classified in accordance with the classification guidelines for the calculator method, the unit-in-place cost method or the segregated cost method.

Both direct costs and indirect costs shall be included where the replacement cost new of a heavy industrial building or structure is determined by the trended original cost method.

Direct costs shall include all labour and materials; site preparation, grading and excavation for the foundation; and connection of utilities that are directly related to the building or structure.

Indirect costs related to the building or structure shall include architectural and engineering fees, permits and plans; survey fees, net sales taxes, service charges and interest on building funds during construction; building supervision and overhead costs, contractor's profit, worker's compensation and unemployment insurance costs; fire and liability insurance, temporary equipment and facilities, and security charges related to the construction of the building or structure.

Costs excluded from the determination of replacement cost new by the trended original cost method are as follows:

- land improvement costs, subdivision and development costs, studies for the project, appraisal or other consulting fees, including:
 - costs related to the purchase or assembly of land and related legal fees, and
 - property taxes, demolition, storm drain charges or rough site grading;
- financing discounts or bonuses, start-up costs, feasibility overhead, and fixture and equipment purchases;
- site improvement costs such as signs, landscaping, paving, walls, lighting, swimming pools or other recreational facilities;
- off site costs including roads, streets and other infrastructure, acreage and subdivision development fees, connection charges, environmental impact or other assessments;
- furnishings, fixtures or equipment not included in the general building contract;
- marketing or real estate expenses to create occupancy; and
- costs considered specialized tenant improvements.

The replacement cost new for heavy industrial buildings and structures using the trended original cost method is determined by application of the following calculation procedure:

1. Determine the original construction cost of the building or structure;
2. Determine the direct and indirect costs requiring an adjustment;
3. Determine the comparative cost factor (see Document 3.1.5) for commercial buildings required to adjust construction costs to January 1, 2019; and
4. Calculate the replacement cost new of the building or structure by adjusting the original construction cost for any direct or indirect costs requiring adjustment and multiplying the adjusted original construction cost by the comparative cost index.

Summary

This section contains the calculation procedures used to calculate the assessed value for heavy industrial buildings and structures after the Replacement Cost New (RCN) has been determined.

Heavy Industrial Buildings and Structures

The following calculation procedure shall be used for heavy industrial buildings and structures.

Description	Document No.	Page No.
(a) Replacement Cost New (RCN)	3.1.2	1-4
(b) Cost Factor	3.1.4	1
(c) $RCN \times Cost\ Factor = a \times b$		
(d) RCN Less Physical Deterioration $= c \times (1 - (d_1 \times d_2))$ d ₁ . Physical Deterioration d ₂ . Condition Rating	3.1.8 3.1.8	1-4 5-6
(e) RCN Less Physical Deterioration, Functional Obsolescence and Closure Adjustment Factor $= (d - (d \times e_1)) \times e_2$ e ₁ . Functional Obsolescence Factor e ₂ . Closure Adjustment Factor	3.1.9 3.1.10	1 1
(f) Assessed Value = e		

Oil & Gas Well Buildings and Structures

The following calculation procedure shall be used for oil and gas well buildings and structures on an oil or gas well site.

Description	Document No.	Page No.
(a) Replacement Cost New (RCN)	3.1.2	1-4
(b) Cost Factor	3.1.4	1
(c) $RCN \times Cost\ Factor = a \times b$		
(d) RCN Less Physical Deterioration = $c \times (1 - d_1)$ d ₁ . Physical Deterioration	3.1.8	1-4
(e) RCN Less Physical Deterioration and Production Adjustment Factor = $d \times e_1$ e ₁ . Production Adjustment Factor	4.1.1	3-5
(f) Assessed Value = e		

Section: General Rules

Heavy Industrial Improvements

Subject: Calculation Procedure after RCN

Section: General Rules

Heavy Industrial Improvements

Subject: Cost Factor

Description

This section contains the valuation procedures for determining the cost factor for all heavy industrial buildings and structures.

Cost Factor Formula

The cost factor is calculated by the following formula:

Cost Factor = Current Cost Multiplier x Local Multiplier x Saskatchewan Cost Factor

Marshall & Swift Valuation Service Commercial Current Cost Multipliers

Calculator Method

When using the calculator method use the Marshall & Swift Valuation Service current cost multipliers in Section 99, page 3, Current Cost Multipliers, Calculator Cost Sections, Central, dated 10/2018.

Segregated Method

When using the segregated method use the Marshall Valuation Service current cost multipliers in Section 99, page 3, Current Cost Multipliers, Segregated Cost Sections, Central, dated 10/2018.

Unit-in-place Method

When using the unit-in-place method use the Marshall Valuation Service current cost multipliers in Section 99, page 3, Current Cost Multipliers, Unit-In-Place Cost Sections 51 to 67, Central, dated 10/2018.

Marshall Valuation Service Commercial Local Multipliers

Apply the Marshall Valuation Service local multipliers from Section 99, page 5, Local Multipliers, Canada, Saskatchewan, dated 10/2018.

The Canadian Tax Removal adjustment in Section 99, page 5, shall not be applied in the determination of Replacement Cost New (RCN) and Assessed values in Saskatchewan.

Saskatchewan Cost Factor

The Saskatchewan Cost Factor is 1.06.

Cost Factor

The Cost Factor (Current Cost Multiplier x Local Multiplier x Saskatchewan Cost Factor) for the following building and structures is 1.00:

- Oil & Gas Well Tanks (S880)
- Oil & Gas Well Buildings (S881)
- Conveyor Gallery (S933)
- Wind Turbine (S940)

Section: General Rules

Heavy Industrial Improvements

Subject: Cost Factor

Section: General Rules

Heavy Industrial Improvements

Subject: Comparative Cost Factor

Description

This section contains the valuation procedures for determining the comparative cost factor for heavy industrial buildings and structures.

Application

Where the replacement cost new for heavy industrial buildings and structures is determined by the trended original cost method, the comparative cost factor shall be applied to adjust the original construction cost to January 1, 2019.

The trended original cost method is used where a specific building or structural attribute cannot be classified in accordance with the classification guidelines for the calculator method, the unit-in-place cost method or the segregated cost method.

Comparative Cost Factor

Year	Class				
	A	B	C	D	S
	Fireproofed Steel Frame	Reinforced Concrete Frame	Masonry Bearing Walls	Wood Frame	Metal Frame
2018 & newer					
2017					
2016					
2015					
2014					
2013					
2012					
2011					
2010					
2009					
2008					
2007					
2006					
2005					
2004					
2003					
2002					
2001					
2000					
1999					
1998					
1997					
1996					
1995					
1994					
1993					
1992					

Section: General Rules

Heavy Industrial Improvements

Subject: Comparative Cost Factor

Year	Class				
	A	B	C	D	S
	Fireproofed Steel Frame	Reinforced Concrete Frame	Masonry Bearing Walls	Wood Frame	Metal Frame
1991					
1990					
1989					
1988					
1987					
1986					
1985					
1984					
1983					
1982					
1981					
1980					
1979					
1978					
1977					
1976					
1975					
1974					

This table is a derivative work based on the “Marshall & Swift Valuation Service” which is the copyrighted material of Marshall & Swift / Published by CoreLogic Inc © 2018. Unauthorized reproduction is expressly prohibited.

Portions of this section are not available for viewing due to licensing with Marshall and Swift. Therefore the factors etc. have been intentionally left blank.

This information is available for purchase by contacting:

Technical Standards and Policy Division
Saskatchewan Assessment Management Agency
200 – 2201 – 11th Avenue
Regina, Saskatchewan S4P 0J8

Phone: (306) 924-8000
Toll Free: 1-800-667-SAMA (7262)
Fax: (306) 924-8070

Email: info.request@sama.sk.ca

Web Site: <http://www.sama.sk.ca>

Section: General Rules

Heavy Industrial Improvements

Subject: Building Height

Description

This section contains the valuation procedures for determining building height adjustments for various types of heavy industrial buildings.

Application

Building height adjustments that may be applied are:

- storey height;
- section height; and
- building height (total number of storeys).

Storey Height

Storey height is the vertical height of the exterior wall, which is measured as follows:

- in a flat roof one storey building, the vertical distance from the top of the floor to the top of the roof;
- in a slant roof building, the average vertical distance from the floor to the top of the roof;
- in a one storey standard gable roof building, the vertical distance from the top of the floor to the top of the exterior wall;
- in a multi-storey building, the vertical distance from the top of the floor to the top of the next floor above; and
- for non-standard or high pitched roofs, by dividing the cubic volume of the building section by the area of the building.

Where the storey height varies from the standard storey height for the building, a storey height factor shall be applied.

The standard storey height and the storey height factor are specified in the structural components and adjustments sections for the specific occupancy codes to which they apply.

Section Height

Section height is the number of storeys in a section of a building, where each storey is constructed to the same construction standard.

Building Height (Total Number of Storeys)

Building height is the total number of storeys for all portions of a building that are attached vertically, excluding below ground portions such as basements. The building height factor shall be applied to all storeys including below ground portions.

The units of measure for building height shall be the number of storeys.

Portions of this section are not available for viewing due to licensing with Marshall and Swift. Therefore the factors etc. have been intentionally left blank.

This information is available for purchase by contacting:

Technical Standards and Policy Division
Saskatchewan Assessment Management Agency
200 – 2201 – 11th Avenue
Regina, Saskatchewan S4P 0J8

Phone: (306) 924-8000
Toll Free: 1-800-667-SAMA (7262)
Fax: (306) 924-8070
Email: info.request@sama.sk.ca
Web Site: <http://www.sama.sk.ca>

Section: General Rules

Heavy Industrial Improvements

Subject: Building Height

Building Height (Total Number of Storeys)	Factor	Building Height (Total Number of Storeys)	Factor
1		26	
2		27	
3		28	
4		29	
5		30	
6		31	
7		32	
8		33	
9		34	
10		35	
11		36	
12		37	
13		38	
14		39	
15		40	
16		41	
17		42	
18		43	
19		44	
20		45	
21		46	
22		47	
23		48	
24		49	
25		≥ 50	

This table is a derivative work based on the “Marshall & Swift Valuation Service” which is copyrighted material of Marshall & Swift / Published by CoreLogic Inc © 2018. Unauthorized reproduction is expressly prohibited.

Section: General Rules

Heavy Industrial Improvements

Subject: Incomplete Construction

Description

This section contains the valuation procedures for determining incomplete construction adjustments for various types of heavy industrial buildings and structures.

Application

The incomplete construction adjustment shall be used to adjust the replacement cost new of buildings or structures that are under construction.

Where the base rate is adjusted for a missing building component, an incomplete construction adjustment for the missing component shall not be included in the calculation of replacement cost new.

Where a building is under construction and the base rate is not adjusted for a missing component, the incomplete construction factor shall be determined using the following formula:

$$\text{Incomplete Construction Factor} = \frac{(\text{Total Construction Cost} - \text{Costs Incurred to Date})}{\text{Total Construction Cost}}$$

Section: General Rules

Heavy Industrial Improvements

Subject: Incomplete Construction

Summary

This section contains the valuation procedures for determining the amount of physical deterioration for heavy industrial buildings and structures.

Application

Physical deterioration is the loss in value from replacement cost new due to wear and tear, decay and structural defects caused by the forces of nature.

Some causes of physical deterioration are normal use, breakage, neglect, infestation of insects, dry rot, moisture, and climatic elements. The occurrence of physical deterioration is dependent on the quality of the workmanship and materials used to construct the building or structure, and the use, abuse and general maintenance of the building or structure since its construction.

Formulas, Rules and Principles

The physical deterioration and condition rating schedules account for all curable and incurable physical deterioration and normal functional obsolescence not accounted for in the replacement cost new of the building or structure.

No additional allowance shall be made for physical deterioration except as may be accounted for in the calculation of the production adjustment factor for oil and gas well site buildings and structures.

Where the total percentage amount of physical deterioration is equal to or greater than the replacement cost new of the building or structure, the amount of physical deterioration is 99 percent.

Physical deterioration may be determined by the age-life method or lifetime method.

Age-Life Method

The age-life method is used where the actual or effective age of the building or structure is known or can be estimated, and the condition of the building or structure can be determined or estimated.

‘Actual age’ is the number of years elapsed since an original structure was built.

‘Effective age’ is the typical age of structures equivalent to the one in question with respect to condition and utility and reflects the remaining economic life of the building or structure. Effective age can be either shorter or longer than actual age.

‘Economic life’, with respect to a building or structure, means the period during which a given building or structure is expected to contribute (positively) to the value of the total property. This period is typically shorter than the period during which the improvement could be left on the property, that is, its physical life. Renovation, remodelling, or rehabilitation can extend a building's physical life and can have an effect on its remaining economic life.

The amount of physical deterioration is determined by application of the following calculation procedure:

1. Determine the normal life expectancy for the class and type of building or structure;
2. Determine the effective age and the percentage amount of deterioration for the class and type of building or structure using the physical deterioration schedules;
3. Determine the condition and condition factor using the condition rating schedule; and
4. Calculate the total percentage amount of physical deterioration by multiplying the amount of physical deterioration from the physical deterioration schedule by the condition factor from the condition rating schedule.

Section: General Rules

Heavy Industrial Improvements

Subject: Physical Deterioration

Lifetime Method

The amount of physical deterioration by the lifetime method for heavy industrial buildings and structures is 40%. The condition rating is 1.0.

The lifetime method is used for the following heavy industrial buildings and structures:

Non-standard heavy industrial buildings and structures:

1. Marshall & Swift Valuation Service
 - Secure Storage Shed: Section 17, page 25
 - Farm Storage: Section 17, pages 54 to 55
 - Tanks: Section 61
 - Miscellaneous Industrial Costs: Section 62, pages 5 to 6

2. SAMA's 2019 Cost Guide
 - Chapter 7: Commercial Tanks and Reservoirs
 - Chapter 8: Commercial Cylindrical Bin (S840)
 - Chapter 8: Commercial Hopper Bin (S841)
 - Chapter 8: Utility Bin (S842)
 - Chapter 8: Utility Hopper Bin (S843)
 - Chapter 9: Stack (S852)
 - Chapter 9: Incinerator (S853)
 - Chapter 9: Mill Incinerator (S854)
 - Chapter 9: Brick Incinerator (S855)
 - Chapter 9: Tower (S860)
 - Chapter 9: Guyed Tower (S861)

3. Saskatchewan Assessment Manual (2019 Base Year)
 - Chapter 3: Oil and Gas Well Tanks (S880)
 - Chapter 3: Oil and Gas Well Buildings (S881)
 - Chapter 3: Utility Tunnel (S932)
 - Chapter 3: Wind Turbine (S940)

Section: General Rules

Heavy Industrial Improvements

Subject: Physical Deterioration

Commercial Building and Structure Physical Deterioration Schedule

Use the physical deterioration schedule in the Marshall & Swift Valuation Service Section 97, Depreciation – Commercial Properties dated December 2016 except for occupancy codes that use a life expectancy from the Specified Commercial Building Life Expectancy Table.

Properties built in 2019 or newer are assigned an effective age of '0'.

For commercial buildings and structures, the following construction classes are used to assign life expectancies from the Specified Commercial Building Life Expectancy Table. The class of construction is the basic subdivision in the Marshall Valuation Service, dividing all buildings into basic cost groups by type of framing.

Construction Class	Construction Class Description
C	Concrete Frame (Masonry) Exterior Wall
D	Wood Frame Exterior Wall
P	Pole Frame Exterior Wall
S	Steel Frame Exterior Wall
W	Steel Frame Exterior Slant Wall

Portions of this section are not available for viewing due to licensing with Marshall and Swift. Therefore the factors etc. have been intentionally left blank.

This information is available for purchase by contacting:

Technical Standards and Policy Division
Saskatchewan Assessment Management Agency
200 – 2201 – 11th Avenue
Regina, Saskatchewan S4P 0J8

Phone: (306) 924-8000
Toll Free: 1-800-667-SAMA (7262)
Fax: (306) 924-8070

Email: info.request@sama.sk.ca

Web Site: <http://www.sama.sk.ca>

Section: General Rules

Heavy Industrial Improvements

Subject: Physical Deterioration

Specified Commercial Building Life Expectancy Table

Occupancy Code	Occupancy Description	Const. Class	Construction Quality			
			Low Cost	Average	Good	Excellent
104	Commodity Warehouse	C				
		D				
		P				
		S				
		W				
123	Seed Processing Storage	D				
		P				
		S				
339	Lumber Storage Shed	D				
		P				
		S				
390	Lumber Storage Building	D				
		P				
		S				
391	Material Storage Building	C				
		D				
		P				
		S				
		W				
420	Bulk Fertilizer Storage	C				
		D				
		P				
		S				
468	Material Storage Shed	C				
		D				
		P				
		S				
		W				
471	Light Commercial Utility Building	C				
		D				
		P				
		S				
554	Shed Office Structure	C				
		D				
		P				
		S				
555	Light Commercial Quonset	D				
		P				
		S				
556	Bulk Oil Storage	D				
		P				
		S				

Condition Rating Schedule

The condition of buildings and structures is determined by taking into consideration the remaining economic life of both short-lived and long-lived items.

Short-lived items have a shorter life than the basic structure, for example roofing, interior finish, floor coverings, heating system and plumbing fixtures.

Long-lived items are in the basic structure of the building and are not usually replaced during the economic life of the building. Long-lived items include such things as the foundation, frame, floor and roof structure, piping, heat ducts, insulation and electrical wiring.

The condition factor for heavy industrial buildings and structures is determined by application of the following condition rating schedule:

Condition Rating	Description	Condition Factor
Excellent	<p><u>Remodelling:</u> Extensive remodelling has occurred in recent years. No functional inadequacies of any consequence.</p> <p><u>Long-lived items:</u> Long-lived items have had good maintenance, remodelling, or renovation where necessary.</p> <p><u>Maintenance:</u> Above normal regular general maintenance has occurred. All items that can normally be repaired or refinished have recently been corrected.</p> <p><u>Short-lived items:</u> All major short-lived items are in like-new condition.</p>	0.5
Superior	<p><u>Remodelling:</u> Some remodelling has occurred in recent years. Little evidence of functional obsolescence and a high degree of utility.</p> <p><u>Long-lived items:</u> Long-lived items have had good maintenance, remodelling or renovation where necessary.</p> <p><u>Maintenance:</u> Above normal regular general maintenance has occurred.</p> <p><u>Short-lived items:</u> Most major short-lived items are in like-new condition.</p>	0.6
Very Good	<p><u>Remodelling:</u> Some remodelling has occurred since construction of the original building. Little evidence of functional obsolescence and a high degree of utility.</p> <p><u>Long-lived items:</u> Long-lived items have been repaired where necessary. No visible evidence of deterioration.</p> <p><u>Maintenance:</u> Normal regular general maintenance has occurred. Many items have been overhauled and repaired as they've shown signs of wear.</p> <p><u>Short-lived items:</u> Many of the major short-lived items are in like-new condition, while others are well maintained and some may require minor repair.</p>	0.7
Good	<p><u>Remodelling:</u> Utility is above the standard.</p> <p><u>Long-lived items:</u> Long-lived items have been repaired where necessary.</p> <p><u>Maintenance:</u> Normal regular general maintenance has occurred. No obvious maintenance required.</p> <p><u>Short-lived items:</u> A few major short-lived items are in like-new condition, while others are well maintained and some may require minor repair.</p>	0.8

Section: General Rules

Heavy Industrial Improvements

Subject: Physical Deterioration

Condition Rating	Description	Condition Factor
Above Average	<p><u>Remodelling:</u> Building is substantially in its original state.</p> <p><u>Long-lived items:</u> Most long-lived items have been repaired where necessary.</p> <p><u>Maintenance:</u> Normal regular general maintenance has occurred.</p> <p><u>Short-lived items:</u> A few major short-lived items are in like-new condition, while others are well maintained and some may require minor repair.</p>	0.9
Average	<p>Irrespective of the following description, new or recently built buildings are considered to be in average condition.</p> <p><u>Remodelling:</u> Building is substantially in its original state. Utility is standard for properties with a similar class and usage.</p> <p><u>Long-lived items:</u> Most long-lived items have been repaired where necessary.</p> <p><u>Maintenance:</u> Normal regular general maintenance has occurred. May have some evidence of deferred maintenance as a few minor repairs and refinishing are needed.</p> <p><u>Short-lived items:</u> A few major short-lived items may require repair or replacement, while others will not require replacement in the short term.</p>	1.0
Below Average (Badly Worn)	<p><u>Remodelling:</u> Building is substantially in its original state. Inadequate building utility and services.</p> <p><u>Long-lived items:</u> Lack of maintenance of long-lived items has resulted in structural decay and defects.</p> <p><u>Maintenance:</u> Deferred general maintenance is apparent. Much repair is needed.</p> <p><u>Short-lived items:</u> Some major short-lived items require repair or replacement, while others show noticeable wear.</p>	1.15
Poor (Worn Out)	<p><u>Remodelling:</u> Building is substantially in its original state. Usually contains numerous functional inadequacies.</p> <p><u>Long-lived items:</u> Lack of maintenance of long-lived items has resulted in structural decay and defects that cannot be economically repaired.</p> <p><u>Maintenance:</u> General maintenance has been neglected.</p> <p><u>Short-lived items:</u> Most short-lived items need major repairs or replacement.</p>	1.3

Summary

This section contains the valuation procedures for determining the amount of functional obsolescence for heavy industrial buildings and structures.

Formulas, Rules and Principles

Functional obsolescence is the loss in value from replacement cost new less physical deterioration due to the inability of the building or structure to adequately perform the function for which it is used.

Functional obsolescence is caused by changes in demand, design and technology that result in a loss in the utility of the building or structure.

No allowance shall be made for functional obsolescence except as may be accounted for in the calculation of functional obsolescence and the calculation of the replacement cost new less physical deterioration.

Functional obsolescence is any functional obsolescence not accounted for in the replacement cost new less physical deterioration. Where there is no functional obsolescence attributed to a building or structure the functional obsolescence factor shall be 1.0.

Functional obsolescence not accounted for in the replacement cost new less physical deterioration shall be accounted for in accordance with the replacement cost method or comparable unit method.

Replacement Cost Method

The amount of obsolescence shall be determined from the replacement cost of a substitute building or structure.

The amount of functional obsolescence shall be determined by application of the following calculation procedure:

1. Determine the replacement cost new less physical deterioration of the building or structure with the functional obsolescence;
2. Determine the replacement cost new less physical deterioration of a substitute building or structure without the obsolescence; and
3. Calculate the functional obsolescence factor by dividing the replacement cost new less physical deterioration of the substitute building or structure by the replacement cost new less physical deterioration of the building or structure with the functional obsolescence.

Comparable Unit Method

The comparable unit method may be used where there is insufficient information to establish functional obsolescence by the replacement cost method. The amount of functional obsolescence shall be determined by comparison to other comparable buildings or structures.

The amount of functional obsolescence shall be determined by application of the following formula:

$$\text{FUNCT}_{\text{SUB}} = \text{FUNCT}_{\text{COMP}}$$

where: $\text{FUNCT}_{\text{SUB}}$ = functional obsolescence for the subject building or structure

$\text{FUNCT}_{\text{COMP}}$ = functional obsolescence for the comparable buildings and structures

Section: General Rules

Heavy Industrial Improvements

Subject: Functional Obsolescence

Summary

This section contains the procedures for determining the closure adjustment factor for heavy industrial buildings and structures.

Description

The closure adjustment factor shall account for all of the loss in value due to a complete closure of a heavy industrial property.

Application

The closure adjustment factor for heavy industrial buildings and structures shall be determined by the schedule of rates method.

Schedule of Rates Method

1. The closure adjustment factor shall only be applied to heavy industrial buildings and structures.
2. The closure adjustment factor shall only be applied where the processes included in the “heavy industrial property” definition have been completely shut down and the entire property is no longer in operation for at least 12, 24 or 36 consecutive months in the year preceding the assessment roll year to which the assessment relates. The schedule of adjustments is as follows:

Factor	Consecutive months of closure
0.75	12
0.50	24
0.25	36

3. The closure adjustment factor shall not be applied in the following circumstances:
 - To any closed portion or unused area of an operating heavy industrial property;
 - For the reduced production output or reduced operating time of a heavy industrial property;
 - To a heavy industrial property that is under construction;
 - For closure of a heavy industrial property caused by an expansion, upgrade, renovation or labour dispute.
4. The closure adjustment factor of 0.25 shall be applied where a heavy industrial property is permanently closed and all equipment is removed by January 1 of the assessment roll year to which the assessment relates. Prior to making this adjustment, written confirmation is required from the property owner or senior executive representing the owner indicating the property is permanently closed.
5. Properties qualifying for the closure adjustment factor which have functional obsolescence applied shall have the closure adjustment factor adjusted so the combined reduction (functional obsolescence and closure adjustment factor) does not exceed 75% of replacement cost new less depreciation (RCNLD) of the heavy industrial buildings and structures.

Section: General Rules

Heavy Industrial Improvements

Subject: Closure Adjustment Factor

Section: Non-Standard

Heavy Industrial Improvements

Subject: Heavy Industrial Buildings and Structures

Summary

This section contains the rate schedules and calculation procedures for heavy industrial buildings and structures that are not to be valued using the Marshall & Swift Valuation Service.

Definition

Non-standard heavy industrial buildings and structures include the following:

1. Located in this chapter:
 - Oil & Gas Well Tanks (S880)
 - Oil & Gas Well Buildings (S881)
 - Utility Tunnel (S932)
 - Conveyor Gallery (S933)
 - Industrial Pipe Rack (S935)
 - Wind Turbine (S940)

2. Occupancy Codes located in Chapters 7, 8 and 9 of SAMA's 2019 Cost Guide.

Rates and Calculation Procedures

SAMA's 2019 Cost Guide is to be used to value the occupancy codes located at a heavy industrial property and found in Chapters 7, 8 and 9 of SAMA's 2019 Cost Guide.

Section: Non-Standard

Heavy Industrial Improvements

Subject: Heavy Industrial Buildings and Structures

Section: Non-Standard

Heavy Industrial Improvements

Subject: Oil and Gas Well Tanks (S880)

Occupancy Description

Tanks may be of various construction and design depending on their particular requirement. They may be steel, either welded or bolted together, fibreglass or concrete. They may be open-topped or closed, cone-bottom or flat, and surface or buried.

Structural Components

Lap Welded Steel Stock Tanks:

Volume (barrels)	Rate (\$/tank)	
	Open Top	Closed Top
≤ 50	13,560	16,480
70	18,310	21,840
90	22,040	26,100
100	22,790	26,790
150	29,380	32,790
200	33,820	37,350
210	38,640	40,420
250	40,250	42,230
300	41,630	43,750
400	55,900	58,750
500	59,450	62,440
750	63,940	67,050
1,000	69,770	85,720
5,000	412,780	435,090
10,000	705,590	743,360
20,000	1,256,210	1,366,820
50,000	2,490,530	2,622,600
≥ 100,000	4,619,450	4,863,610
Rates include: <ul style="list-style-type: none"> - lap welded steel - clean out door - fittings - installation - standard deck - secondary containment - flanges and valves - base - flat bottom - 300 ft. of pipe - foundation band Rates do not include insulation and heater.		

Section: Non-Standard

Heavy Industrial Improvements

Subject: Oil and Gas Well Tanks (S880)

Galvanized and Bolted Painted Stock Tanks:

Volume (barrels)	Rate (\$/tank)					
	Galvanized			Bolted Painted		
	Open Top	Cone Deck & Bottom	Flat Bottom	Open Top	Cone Deck & Bottom	Flat Bottom
≤ 100	19,470	20,850	21,520	17,960	21,930	19,390
200	25,560	30,620	31,690	23,600	32,020	28,480
250	27,470	39,940	37,540	25,860	35,580	33,520
500L (low)	37,460	55,280	52,480	32,850	47,680	45,330
500H (high)	47,880	50,610	49,890	41,770	44,050	43,740
750	53,950	63,540	56,660	46,430	63,510	59,130
1,000L (low)	64,510	91,850	76,210	57,750	78,780	67,540
1,000H (high)	63,650	67,500	67,360	51,870	57,750	57,710
1,500	86,370	99,160	93,550	71,940	86,540	80,630
2,000	108,430	122,290	115,480	88,100	106,080	98,640
≥ 5,000	185,620	209,380	197,520	171,510	206,800	192,150
Rates include: <ul style="list-style-type: none"> - thief hatch and vacuum valve - 20 in. dome with cover - tank flanges and valves - base - secondary containment - flush type extended clean out door - inside ladder - foundation bands - installation 						

Section: Non-Standard

Heavy Industrial Improvements

Subject: Oil and Gas Well Tanks (S880)

Open Top Plastic Stock Tanks:

Volume (barrels)	Rate (\$/tank)
≤ 100	19,800
200	25,100
250	29,940
500L (low)	46,080
500H (high)	38,330
750	46,070
1,000L (low)	63,180
1,000H (high)	60,310
1,500	80,820
2,000	96,290
≥ 5,000	187,390
Rates include: <ul style="list-style-type: none"> - thief hatch and vacuum valve - 20 in. dome with cover - tank flanges and valves - base - flush type extended clean out door - inside ladder - foundation bands - secondary containment - installation 	

Section: Non-Standard

Heavy Industrial Improvements

Subject: Oil and Gas Well Tanks (S880)

In-Ground Steel, Fibreglass or Concrete Tanks:

Volume (barrels)	Rate (\$/tank)	
	Closed Top	Open Top
≤ 50	17,190	13,720
100	25,450	20,650
200	35,710	30,910
300	48,090	39,170
400	56,360	46,040
500	62,620	51,540
750	87,260	71,680
1,000	112,710	92,850
1,500	184,920	151,210
2,000	204,770	168,670
≥ 3,000	276,310	226,750
Rates include: <ul style="list-style-type: none"> - pipes - valves - fittings - installation 		

Section: Non-Standard

Heavy Industrial Improvements

Subject: Oil and Gas Well Tanks (S880)

Chemical Storage Tanks:

Volume (imp. gal.)	Rate (\$/tank)
≤ 65	1,510
100	1,750
150	2,020
200	2,370
250	2,830
500	3,770
1,000	6,900
2,000	10,910
≥ 3,000	14,120
Rates include: <ul style="list-style-type: none"> - tank - valves - fittings - stand - pipes - installation 	

Fibreglass Vertical Closed Top Tanks:

Volume (barrels)	Volume (M ³)	Height (ft.) x Width (ft.)	Rate (\$/tank)
≤ 90	14.3	8.0 x 10	23,030
100	15.9	8.5 x 10	24,260
140	22.3	10.0 x 10	27,300
150	23.9	10.5 x 10	27,950
200	31.8	11.0 x 11	31,780
210	33.4	11.5 x 11	33,440
300	47.7	11.5 x 16	41,730
400	63.6	11.5 x 21	50,990
500	79.5	11.5 x 27	67,910
750	119.2	15.5 x 22	99,590
≥ 1,000	158.9	15.5 x 30	116,060
Rates include: <ul style="list-style-type: none"> - tank - secondary containment - freight - installation 			

Section: Non-Standard

Heavy Industrial Improvements

Subject: Oil and Gas Well Tanks (S880)

Fibreglass Horizontal Tanks:

Volume (barrels)	Volume (M ³)	Rate (\$/tank)
≤ 100	15.9	40,930
150	23.9	56,190
≥ 200	31.8	66,300
Rates include:		
<ul style="list-style-type: none"> - tank - secondary containment - freight - installation 		

Fibreglass Open Top Tanks:

Volume (barrels)	Volume (M ³)	Rate (\$/tank)
≤ 90	14.3	21,610
100	15.9	21,990
140	22.3	24,030
≥ 210	33.4	31,340
Rates include:		
<ul style="list-style-type: none"> - tank - secondary containment - freight - installation 		

Open Top Plastic Pop Tanks:

Volume (barrels)	Rate (\$/tank)
40	3,420
120	9,210
Rates include:	
<ul style="list-style-type: none"> - tank - secondary containment - freight - installation 	

Section: Non-Standard

Heavy Industrial Improvements

Subject: Oil and Gas Well Tanks (S880)

Propane Vessels (Gas Bullets):

Volume (USG)	Rate (\$/tank)
≤ 500	13,630
1,000	18,050
2,000	30,970
6,500	75,840
9,000	91,230
12,000	112,110
15,000	131,890
20,000	164,870
30,000	230,810
45,000	330,270
60,000	427,810
≥ 90,000	628,400
Rates include:	
- painted tank	- saddles
- concrete piers	- installation

Section: Non-Standard

Heavy Industrial Improvements

Subject: Oil and Gas Well Tanks (S880)

Insulation and Lining:

Volume (barrels)	Rate (\$/tank)		
	Urethane	Fibreglass c/w Metal Wrap	Epoxy
≤ 50	1,170	4,260	8,210
65	1,240	5,480	10,190
90	1,730	6,660	13,410
100	1,730	7,290	14,490
165	2,350	10,920	21,440
200	2,760	12,740	24,040
210	2,930	13,330	26,290
240	3,450	15,180	29,970
300	4,600	18,230	37,790
400	5,220	21,260	41,820
500	5,810	23,710	46,580
750	8,150	32,810	65,450
1,000	8,660	35,860	71,520
1,500	11,610	49,840	98,640
2,000	12,750	53,440	105,660
3,000	17,390	71,690	141,520
4,000	20,280	85,650	169,360
5,000	23,810	99,640	197,270
≥ 10,000	38,360	106,300	211,230

Stairways, Walkways and Stiles:

Description	Rate (\$/unit)
Stairways	3,820
Walkways	7,110
Stiles	3,890

Section: Non-Standard

Heavy Industrial Improvements

Subject: Oil and Gas Well Tanks (S880)

Tank Gauges:

Description	Rate (\$/unit)
Electronic - Gauge Head Assembly (dial type)	9,730
- Hi-low transmitter	3,050
Floating - Gauge Board Assembly (target type)	6,930
- Hi-low float assembly	1,600
Liquid Level Seal (sour gas application)	3,450

Tank Heaters:

Description	Rate (\$/unit)
U-Fire Tubes 6"	25,010
U-Fire Tubes 10"	28,860
Straight Fire Tube or Electric	16,260
Rates include:	
- stack	
- flame arrestor	
- burner	
- installation	

Calculation Procedure

Description	Document No.	Page No.
(a) Base Rate	3.2.2	1-7
(b) Additional Features = (b ₁ + b ₂ + b ₃ + b ₄)	3.2.2	
b ₁ . Insulation and Lining	3.2.2	8
b ₂ . Stairways, Walkways and Stiles	3.2.2	8
b ₃ . Tank Gauges	3.2.2	9
b ₄ . Tank Heaters	3.2.2	9
(c) Replacement Cost New = a + b		

Section: Non-Standard

Heavy Industrial Improvements

Subject: Oil and Gas Well Tanks (S880)

Section: Non-Standard

Heavy Industrial Improvements

Subject: Oil and Gas Well Buildings (S881)

Description

Oil and gas well buildings are metal and wood sheds used to house or shelter the fixtures, machinery, tools and other appliances, and field offices.

Structural Components

Wood Sheds:

Area (sq.ft)	Rate (\$/sq.ft.)					
	Frame	Lining & Insulation	Floor	Heating	Electrical	Total
≤ 50	106.30	19.85	12.20	12.10	26.20	176.65
100	98.60	16.65	12.20	11.90	25.95	165.30
200	90.45	14.60	12.20	14.20	25.10	156.55
300	79.15	12.45	12.20	18.15	24.50	146.45
400	69.05	10.75	12.20	18.05	23.90	133.95
500	62.50	9.75	12.20	16.65	22.95	124.05
600	59.60	9.20	12.20	14.60	22.15	117.75
700	58.65	8.95	12.20	13.50	21.45	114.75
800	57.95	8.80	12.20	12.60	20.65	112.20
900	57.15	8.65	12.20	11.60	19.80	109.40
1,000	56.55	8.50	12.20	10.35	18.90	106.50
1,100	55.75	8.45	12.20	9.25	18.15	103.80
1,200	55.50	8.35	12.20	8.55	17.15	101.75
1,300	55.15	8.30	12.20	8.05	16.65	100.35
1,400	54.70	8.20	12.20	7.55	15.75	98.40
1,500	54.30	8.15	12.20	7.35	14.70	96.70
1,600	54.30	8.10	12.20	7.05	14.30	95.95
1,700	54.30	8.10	12.20	6.55	13.50	94.65
1,800	53.85	8.10	12.20	6.35	12.85	93.35
1,900	53.65	8.10	12.20	6.25	12.00	92.20
2,000	53.50	8.05	12.20	6.05	11.40	91.20
2,100	53.40	8.05	12.20	5.95	10.90	90.50
2,200	53.15	7.95	12.20	5.55	10.20	89.05
2,300	52.85	7.90	12.20	5.45	9.60	88.00
2,400	52.40	7.90	12.20	5.35	8.80	86.65
2,500	52.30	7.85	12.20	5.25	8.15	85.75
2,600	51.90	7.85	12.20	5.15	7.45	84.55
2,700	51.80	7.80	12.20	5.05	6.85	83.70
2,800	51.70	7.75	12.20	4.95	6.25	82.85
2,900	51.60	7.70	12.20	4.85	5.60	81.95
3,000	51.55	7.65	12.20	4.75	4.90	81.05
3,100	51.50	7.60	12.20	4.65	4.15	80.10
3,200	51.15	7.55	12.20	4.65	3.95	79.50
> 3,200	47.15	7.00	12.20	2.20	3.45	72.00

Rates include:

- walls and roof with 2"x4" studs at 16" o.c.
- good siding and asphalt shingles
- 2 standard walk-in doors with panic hardware
- plywood or equivalent sheathing
- adequate electrical service
- 2 standard windows

Section: Non-Standard

Heavy Industrial Improvements

Subject: Oil and Gas Well Buildings (S881)

Metal Shed:

Area (sq.ft.)	Rate (\$/sq.ft.)						
	Frame	Steel Frame	Lining & Insulation	Floor	Heating	Electrical	Total
≤ 100	60.35	15.25	19.55	11.65	9.75	20.75	137.30
500	52.75	15.25	18.10	11.65	7.85	18.25	123.85
700	42.55	15.25	18.05	11.65	5.10	17.00	109.60
1,000	40.60	15.15	16.00	11.65	3.95	15.25	102.60
1,300	36.15	15.00	15.20	11.65	2.90	13.65	94.55
≥ 1,800	34.05	17.00	14.10	11.65	2.35	11.65	90.80

Field Office:

Area (sq.ft.)	Rate (\$/sq.ft.)	Area (sq.ft.)	Rate (\$/sq.ft.)
≤ 100	172.00	500	115.70
150	145.35	550	112.35
200	132.05	600	109.60
250	126.00	700	105.40
300	121.15	800	101.75
350	120.30	1,000	95.10
400	119.90	1,200	89.65
450	118.10	> 4,000	79.95

Rates include: Standard mobile unit with blocking and adequate electrical and heating. Typical brand names are Atco and Prebilt.

Miscellaneous Buildings:

Description	Units of Comparison	Rate (\$/sq.ft.)
Fibreglass wellhead shelters	Floor area	120.30
Pump shacks	Floor area	103.05
Utilodor insulated pipe enclosure	Surface area	10.25

Section: Non-Standard

Heavy Industrial Improvements

Subject: Oil and Gas Well Buildings (S881)

Adjustments

Storey Height:

Height (ft.)	Factor
8	0.92
10	1.00
12	1.08
14	1.16
16	1.24
18	1.32
20	1.40
≥ 22	1.48

Doors:

Description	Rate (\$/unit)
Walk-in Door	1,950
Overhead Door	2,630
Window	1,050
Plumbing (3 fixtures)	4,000

Calculation Procedure

Description	Document No.	Page No.
(a) Base Rate = (a ₁ + a ₂ + a ₃ + a ₄ + a ₅ + a ₆)		
a ₁ . Frame Rate	3.2.3	1-2
a ₂ . Steel Frame Rate	3.2.3	2
a ₃ . Insulation and Lining Rate	3.2.3	1-2
a ₄ . Floor Rate	3.2.3	1-2
a ₅ . Heating Rate	3.2.3	1-2
a ₆ . Electrical Rate	3.2.3	1-2
(b) Section Area		
(c) Value Subtotal = a x b		
(d) Storey Height Factor	3.2.3	3
(e) Additional Features = (±e ₁)		
e ₁ . Door Adjustment	3.2.3	3
(f) Replacement Cost New = (c x d) ± e		

Section: Non-Standard

Heavy Industrial Improvements

Subject: Oil and Gas Well Buildings (S881)

Section: Non-Standard

Heavy Industrial Improvements

Subject: Utility Tunnel (S932)

Occupancy Description

Utility tunnels carry utilities between buildings. The rates vary depending on wall thickness.

The rates are averages of reinforced concrete-lined tunnels per cubic foot of tunnel, including drainage.

Structural Components

Utility Tunnel:

Class	Description	Rate (\$/cu.ft.)
A	7" - 10" concrete wall	
B	5" - 7" concrete wall	
C	3" - 5" concrete wall	

Electrical and Mechanical Installations:

Description	Rate (\$/cu.ft.)
Electrical / Lighting	
Heating	
Sprinkler	

Calculation Procedure

Description	Document No.	Page No.
(a) Structure Rate = (a ₁ + a ₂ + a ₃ + a ₄)		
a ₁ . Base Rate	3.2.4	1
a ₂ . Electrical Rate	3.2.4	1
a ₃ . Heating Rate	3.2.4	1
a ₄ . Sprinkler Rate	3.2.4	1
(b) Building Volume	3.1.2	1-2
(c) Value Subtotal = a x b		
(d) Incomplete Construction Factor	3.1.7	1
(e) Replacement Cost New = c- (c x d)		

Portions of this section are not available for viewing due to licensing with Marshall and Swift. Therefore the factors etc. have been intentionally left blank.

This information is available for purchase by contacting:

Technical Standards and Policy Division
Saskatchewan Assessment Management Agency
200 – 2201 – 11th Avenue
Regina, Saskatchewan S4P 0J8

Phone: (306) 924-8000
Toll Free: 1-800-667-SAMA (7262)
Fax: (306) 924-8070

Email: info.request@sama.sk.ca

Web Site: <http://www.sama.sk.ca>

Section: Non-Standard

Subject: Utility Tunnel (S932)

Heavy Industrial Improvements

Section: Non-Standard

Heavy Industrial Improvements

Subject: Conveyor Gallery (S933)

Occupancy Description

A conveyor gallery is a structure primarily found in processing operations used for enclosing conveyor belting that interconnects various buildings.

Rates are based on completely installed units including typical wall, roof, floor, and support structure where designated by type.

Structural Components

Conveyor Gallery:

Type	Class	Life Expectancy (Years)	Rate (\$/cu.ft.)
Elevated (ELEV)	A	40	28.88
Elevated (ELEV)	B	35	23.74
Elevated (ELEV)	C	35	18.56
Surface (SURF)	A	40	24.76
Surface (SURF)	B	35	19.61
Surface (SURF)	C	35	15.48
Suspended (SUSP)	A	40	24.76
Suspended (SUSP)	B	35	19.61
Suspended (SUSP)	C	35	15.48

Electrical and Mechanical Installations:

Description	Rate (\$/cu.ft.)
Electrical	7.61
Heating	4.50
Sprinkler	6.55

Calculation Procedure

Description	Document No.	Page No.
(a) Structure Rate = (a ₁ + a ₂ + a ₃ + a ₄)		
a ₁ . Base Rate	3.2.5	1
a ₂ . Electrical Rate	3.2.5	1
a ₃ . Heating Rate	3.2.5	1
a ₄ . Sprinkler Rate	3.2.5	1
(b) Building Volume	3.1.2	1-2
(c) Value Subtotal = a x b		
(d) Incomplete Construction Factor	3.1.7	1
(e) Replacement Cost New = c - (c x d)		

Section: Non-Standard

Heavy Industrial Improvements

Subject: Conveyor Gallery (S933)



Elevated

Section: Non-Standard

Heavy Industrial Improvements

Subject: Industrial Pipe Rack (S935)

Occupancy Description

Pipe racks are supporting structures for overhead piping and wiring.

Structural Components

Frame:

Type	Class	Description	Life Expectancy	Base Rate (\$/sq.ft.)
5	AA-Excellent	Heavy steel frame	45	18.63
	A-Good	Good steel frame	40	14.30
	B-Average	Average structural steel frame	35	10.98
	C-Low Cost	Light structural steel frame or post	35	8.48

Adjustments

Standard Storey Height: 8 feet

Incomplete Construction: See Doc. No. 3.1.7

Storey Height:

Height (ft.)	Factor	Height (ft.)	Factor	Height (ft.)	Factor
6.00		18.00		55.00	
7.00		19.00		60.00	
8.00		20.00		65.00	
9.00		22.00		70.00	
10.00		24.00		75.00	
11.00		26.00		80.00	
12.00		28.00		85.00	
13.00		30.00		90.00	
14.00		35.00		95.00	
15.00		40.00		100.00	
16.00		45.00		150.00	
17.00		50.00		> 200.00	
See General Rules, Doc. No. 3.1.6					

This table is a derivative work based on the “Marshall & Swift Valuation Service” which is copyrighted material of Marshall & Swift / Published by CoreLogic Inc © 2018. Unauthorized reproduction is expressly prohibited.

Portions of this section are not available for viewing due to licensing with Marshall and Swift. Therefore the factors etc. have been intentionally left blank.

This information is available for purchase by contacting:

Technical Standards and Policy Division
 Saskatchewan Assessment Management Agency
 200 – 2201 – 11th Avenue
 Regina, Saskatchewan S4P 0J8
 Phone: (306) 924-8000
 Toll Free: 1-800-667-SAMA (7262)
 Fax: (306) 924-8070
 Email: info.request@sama.sk.ca
 Web Site: <http://www.sama.sk.ca>

Section: Non-Standard

Heavy Industrial Improvements

Subject: Industrial Pipe Rack (S935)

Calculation Procedure

Description	Document No.	Page No.
(a) Structure Rate = (a ₁)		
a ₁ . Base Rate	3.2.6	1
(b) Section Area	3.1.2	1-2
(c) Adjusted Building Height Factor = c ₁ x c ₂ x c ₃		
c ₁ . Storey Height Factor	3.2.6	1
c ₂ . Total Number of Storeys Factor	3.1.6	2
c ₃ . Number of Storeys	3.1.6	1
(d) Value Subtotal = a x b x c		
(e) Incomplete Construction Factor	3.1.7	1
(f) Replacement Cost New = d – (d x e)		



Class S (5) Excellent Quality (AA)



Class S (5) Good Quality (A)



Class S (5) Average Quality (B)

Section: Non-Standard

Heavy Industrial Improvements

Subject: Wind Turbine (S940)

Occupancy Description

A horizontal axis wind turbine (HAWT) is a rotary device that extracts energy from the wind for electric power generation for public and /or industrial consumption. A wind turbine can be a single turbine or multiple turbines in a wind farm.

The wind turbine assessment is based on the nameplate capacity in megawatts (MW) multiplied by the base rate. Wind turbines typically range in nameplate capacity from 0.50 MW to 4.0 MW.

The rates include the fully installed cost of the foundation, tower and nacelle (supporting, housing and sheltering the power generating equipment).

Rates

Wind turbines are valued at \$500,000/megawatt.

Calculation Procedure

Description	Document No.	Page No.
(a) Structure Rate = a		
a. Base Rate	3.2.7	1
(b) Nameplate Capacity (MW)	3.2.7	1
(c) Value Subtotal = a x b		
(d) Incomplete Construction	3.1.7	1
(e) Replacement Cost New = c – (c x d)		

Section: Non-Standard

Heavy Industrial Improvements

Subject: Wind Turbine (S940)



Horizontal Axis Wind Turbine (0.66 MW)